

MARTIN MARIETTA MATERIALS INC

Form 8-K

April 20, 2011

**Table of Contents**

**UNITED STATES  
SECURITIES AND EXCHANGE COMMISSION  
WASHINGTON, DC 20549  
FORM 8-K  
CURRENT REPORT PURSUANT  
TO SECTION 13 OR 15(D) OF THE  
SECURITIES EXCHANGE ACT OF 1934  
Date of report (Date of earliest event reported) April 14, 2011  
Martin Marietta Materials, Inc.**

(Exact Name of Registrant as Specified in Its Charter)  
**North Carolina**

(State or Other Jurisdiction of Incorporation)

**1-12744**

(Commission File Number)

**56-1848578**

(IRS Employer Identification No.)

**2710 Wycliff Road, Raleigh, North Carolina**

(Address of Principal Executive Offices)

**27607**

(Zip Code)

**(919) 781-4550**

(Registrant's Telephone Number, Including Area Code)

**Not Applicable**

(Former Name or Former Address, if Changed Since Last Report)

Check the appropriate box below if the Form 8-K filing is intended to simultaneously satisfy the filing obligation of the registrant under any of the following provisions:

- Written communications pursuant to Rule 425 under the Securities Act (17 CFR 230.425)
- Soliciting material pursuant to Rule 14a-12 under the Exchange Act (17 CFR 240.14a-12)
- Pre-commencement communications pursuant to Rule 14d-2(b) under the Exchange Act (17 CFR 240.14d-2(b))
- Pre-commencement communications pursuant to Rule 13e-4(c) under the Exchange Act (17 CFR 240.13e-4(c))

**TABLE OF CONTENTS**

Item 8.01 Other Events  
SIGNATURES

---

**Table of Contents**

**Item 8.01 Other Events.**

On April 14, 2011, the Corporation received an imminent danger order issued by the Mine Safety and Health Administration under section 107(a) of the Federal Mine Safety and Health Act of 1977 at its Rocky Point quarry in Rocky Point, North Carolina. The order was issued when a section of high voltage power line cable was observed lying on the ground and along the edge of the mine's entrance road. The cable was attached to the top of the power pole and the portion on the ground was approximately 3 feet to 4 feet from the energized A/C transformer connectors. Although the Plant Manager called the power company, the area was not guarded or barricaded to prevent entry. The order was lifted after the power company repaired the cable.

---

**Table of Contents**

**SIGNATURES**

Pursuant to the requirements of the Securities Exchange Act of 1934, the registrant has duly caused this report to be signed on its behalf by the undersigned hereunto duly authorized.

MARTIN MARIETTA MATERIALS, INC.  
(Registrant)

Date: April 20, 2011

By: /s/ Anne H. Lloyd  
Anne H. Lloyd,  
Executive Vice President and  
Chief Financial Officer